

Maxxam Job #: B685266  
Report Date: 2016/09/30

District of Ucluelet

**MICROBIOLOGY (DRINKING WATER)**

<b>Maxxam ID</b>			PQ1014	PQ1015	PQ1016			
<b>Sampling Date</b>			2016/09/28 08:30	2016/09/28 08:45	2016/09/28 09:00			
<b>COC Number</b>			003521	003521	003521			
	<b>UNITS</b>	<b>MAC</b>	<b>HIGHWAY RESERVOIR</b>	<b>BLACK ROCK</b>	<b>HELEN LIFT STATION</b>	<b>RDL</b>	<b>QC Batch</b>	<b>MDL</b>

<b>Microbiological Param.</b>								
Total Coliforms	MPN/100mL	<1	<1	<1	<1	1	8417483	N/A
E. coli	MPN/100mL	<1	<1	<1	<1	1	8417483	N/A
No Fill	No Exceedance							
Grey	Exceeds 1 criteria policy/level							
Black	Exceeds both criteria/levels							
RDL = Reportable Detection Limit								
N/A = Not Applicable								